

October 30, 2009

AL'S CONCRETE PRODUCTS, INC.  
CHARLES MACH  
800 TOWNHALL ROAD  
LA CRESCENT MN 55947

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: AL'S CONCRETE PRODUCTS, INC.  
Product Name: SEPTIC, HOLDING, PUMP & SIPHON\*  
Model Number(s): 750 **LP**  
(37.0" L.L., 21.1 GAL/IN., 96" MAX. DEPTH OF BURY, 373 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; **TANK DIMENSIONS = 84 IN. L X 72 IN. W X 58 IN. H; ACTUAL CAPACITY IN GALS.: 777 SEPTIC, 820 HOLDING, PUMP AND SIPHON; \* FLOAT SIPHON 8 IN. DRAWDOWN= 168 GAL./DOSE; FLUID DYNAMICS SIPHON 7 IN. DRAWDOWN, 147 GAL./DOSE)**  
Product File No: 20090359

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MARCH 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four inch discharge opening in riser.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Six inch inlet and outlet openings.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
  - Dual inlets at end of tank with one access opening above both inlets.
  - Dual inlets at end of tank with one access opening above each inlet.
  - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

AL'S CONCRETE PRODUCTS, INC.

Page 2

October 30, 2009

PRODUCT FILE NO. 20090359

- Department approved plastic risers and covers installed as required by product approval for the plastic risers and covers with the first riser cast into cover at time of tank production.
- Bedding: A minimum of 4 in. sand or gravel bedding overlying a firm and uniform base is recommended, unless otherwise specified. Tanks should not bear on large boulders or massive rock edges. Correct compaction of bedding material is critical to ensure there is no differential settling.

This approval supersedes the approval issued on 3/20/2005 under product file number 20050133.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050133.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov